



CITY OF SAINT PAUL

375 Jackson Street, Suite 220
Saint Paul, MN 55101- 1806

Telephone: 651- 266- 8989
Facsimile: 651- 266- 9124
www.stpaul.gov/dsi

Code Compliance Report

March 05, 2020

**** This Report must be Posted
on the Job Site ****

Tcc Vic Llc
2401 Lowry Ave Ne Ste 206
St Anthony MN 55418- 2200

Re: 825 University Ave W
File#: 09 058339 VB2

Dear Property Owner:

The following is the Code Compliance report you requested on .

Please be advised that this report is accurate and correct as of the date . All deficiencies identified by the City after this date must also be corrected and all codes and ordinances must be complied with. This report is valid for 365 days from . This report may be used in lieu of a Truth in Housing Report required in St Paul Legislative Code 189. This building must be properly secured and the property maintained at all times.

In order to sell or reoccupy this property the following deficiencies must be corrected. A Legislative Code exemption (Chapter 33.03(f)) allows a Category 2 Vacant Building to be sold "as is" providing the buyer, prior to closing, completes an approval process. For further information, call Reid Soley at 651- 266- 9120.

BUILDING Inspector: Nathan Bruhn

Phone: 651- 266- 9033

1. Insure basement cellar floor is even, is cleanable, and all holes are filled. SPLC 34.10 (1)
2. Tuck Point interior/exterior of foundation as necessary. SPLC 34.09 (1)
3. Repair chimney in an approved manner. SPLC 34.09 (1)
4. North wall of basement level needs removal and rebuild or repair.
5. The floor/ ceiling assembly at north end of basement over boiler area needs removal and rebuild or repair.
6. All plans submitted must address these deficiencies.
7. A building permit is required to correct the above deficiencies. All work is to be done in a workmanship like manner. SPLC 33.03 (a)

This is a registered vacant building. In order to sell or reoccupy this building, all deficiencies listed on this code compliance report must be corrected in accordance with the Minimum Housing Standards of the St. Paul Legislative Code (Chapter 34) and all required permits must receive final approval within six (6) months of the date of this report. One (1) six-month time extension may be requested by the owner and will be considered if it can be shown that the code compliance work is proceeding and is more than fifty (50) percent complete in accordance with Legislative Code Section 33.03(f).

You may file an appeal to this notice by contacting the City Clerk's Office at 651-266- 8688. Any appeal must be made in writing within 10 days of this notice. (You must submit a copy of this notice when you appeal, and pay a filing fee.)

If you have any questions regarding this inspection report, please contact Nathan Bruhn between 7:30 - 9:00 AM at 651- 266- 9046 or leave a voice mail message.

Sincerely,

Nathan Bruhn
Code Compliance Officer
Department of Safety and Inspections
City of Saint Paul
375 Jackson Street, Suite 220
Saint Paul MN 55101
Phone: 651- 266- 9033
Email: nathan.bruhn@ci.stpaul.mn.us

Attachments