



October 20, 2023

Michael Bosick
1753 JAMES ROAD
MENDOTA HEIGHTS MN 55118USA

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 145 BELVIDERE ST E
Ref. # 117657

Dear Property Representative:

Your building was determined to be a registered vacant building on October 20, 2023. Since certificates are for the occupancy of buildings, it has become necessary to revoke the Certificate of Occupancy.

Saint Paul Legislative Code provides that no building shall be occupied without a Certificate of Occupancy. In order to re-occupy the building, the following deficiencies (if applicable) must be corrected and a complete Certificate of Occupancy inspection will be required.

DEFICIENCY LIST

1. 1st and 2nd floor - MN Stat. 299F.362, MSFC 1103.8 - Immediately provide and maintain a smoke alarm located outside each sleeping area.
2. Both south exit doors - SPLC 34.09(4), 34.33 (3) - Repair and maintain the door in good condition. Repair or replace the door seals on the inner exit door. Repair the door frame and install seals on the outer exit door.
3. Kitchen - SPLC 34.10 (7) - Repair and maintain the cabinets in an approved manner. Repair or replace the missing cabinet door and drawer front.
4. Living room - SPLC 34.10 (7), 34.17 (5) - Repair and maintain the ceiling in an approved manner. **Repair the damaged ceiling near the exit door.**
5. Multiple locations - MN Stat. 299F.51 - Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturer's instructions.

6. Multiple locations - SPLC 34.09 (1)(2)(a), 34.33 (1)(b) - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint. **Scrape and paint where needed.**
7. South exterior stairs - SPLC 34.09 (3), 34.33(2) - Repair or replace the damaged handrail in an approved manner. This work may require a permit(s). Call DSI at (651) 266-8989.
8. Sec. 40.06. - Suspension, revocation and denial. (a)Grounds for revocation. The fire code official may, in writing, issue a notice to the owner(s) and known interested parties of the city's suspension or revocation of a fire certificate of occupancy issued under the provisions of this code, or deny an application therefor:(3)If it is found upon inspection of the fire code official that the building or occupancy is in violation of provisions of this or other applicable safety codes, ordinances, rules and regulations. **Revocation due to but not limited to long term non-compliance.**

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: travis.almsted@ci.stpaul.mn.us or call me at 651-266-8977 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Travis Almsted
Fire Safety Inspector II

Ref. # 117657